



MAKES ON PRESSURE RISE

RECOMMENDED SETTINGS: 50 PSI DIFFERENTIAL

MAKES AT 200 PSI
BREAK AT 150 PSI

NOTE 1: FIELD SUPPLIED DISCONNECT REQUIRED.

LEGEND	
M	MOTOR
Cc	OUTDOOR FAN CONTACTOR COIL
C	OUTDOOR FAN CONTACTOR
—	LOW VOLTAGE FACTORY WIRING
---	HIGH VOLTAGE FIELD SUPPLIED
⊗	TERMINAL CONNECTION

Changed Temp. Controller	08/26/95	MSU
Revisions	Date	By
DRY AIRE SYSTEMS		
Drn: DWS	Ckd: MTW	Ap'vd: JJP
Date: 04/02/89	Scale: Full	No: 090-1101-16
Outdoor Condenser OC-50-3 PH		